

Product Type Approval Certificate

Full


This certificate is issued to:

Supplier name and address:	Olex Australia Pty Limited Level 15/300 La Trobe Street, Melbourne Victoria 3000
-----------------------------------	---

In respect of:

Manufacturer:	Nexans (Yanggu) New Rihui Cable Co. Ltd
Place of manufacture:	No. 14, Xihu, Yanggu, Liaocheng City, Shandong, China
Product description:	Nexans Olex Product Code XHZP26RBH01CXAA – 1 Conductor 240 mm ² stranded compacted plain annealed copper, semiconductive conductor screen (0.3 mm min wall), 3.8/6.6 kV TR-XLPE insulated (2.6 mm nom wall), HD Polyethylene sheathed (2.0 mm min wall), HFS-90-TP sheathed (2.0 mm min wall), to AS/NZS 1429.1 where applicable and TfNSW standards T HR EL 20001 ST and T HR EL 20002 ST (RHE-2 cable for use on a 1500V DC system only)
Use approved for:	Applications in accordance with T HR EL 20002 ST
Conditions of approval:	Approval applies to ASA evaluated material grades only – details held by ASA. Changes to insulation and sheath material grades for use in this cable item require resubmission to ASA for technical evaluation.
Limitations:	NA

Evaluating rail transport operator

Name:	Terry Niemeier
Position:	Lead Electrical Engineer, Asset Standards Authority, Transport for NSW
Signature:	
Date:	11/06/2019

Product approval pack reference number: fA745753