

Product Type Approval Certificate

Full

This certificate is issued to:

Supplier name and address:	Raychem (TE Connectivity) Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
-----------------------------------	---------------------------------------------------------------------------------

In respect of:

Manufacturer:	Raychem (TE Connectivity)
Place of manufacture:	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
Product description:	Raychem ESD-8376-AU-6/21 – 11 kV joint for 1-core polymeric insulated cables with wire screen and composite sheath, 95-240 mm ²
Use approved for:	11 kV joint for 1C (95 mm ² – 240 mm ²) XLPE cables, complying with T HR EL 20001 ST
Conditions of approval:	Joint kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
Limitations:	NA

Evaluating rail transport operator

Name:	Lidija Dumbaloska
Position:	Director Energy Networks and Systems, Asset Management, Transport for NSW
Signature:	<i>L. Dumbaloska</i>
Date:	30/06/2021

Product approval pack reference number: fA1415015